

CELLULE	NUMERO CANTON	SUPERFICIE CANTON	CALCUL DESENFUMAGE 2%	NOMBRE EXUTOIRE	SURFACE UTILE EXUTOIRES	DESENFUMAGE CANTON LE PLUS GRAND	PORTES SECTIONNELLES 27 M ²		PORTE SECTIONNELE QUAI 3 X 3		PORTE SIMPLE		PORTE DOUBLE		AMENEE D'AIR
							QTE	SURFACE	QTE	SURFACE	QTE	SURFACE	QTE	SURFACE	
CELLULE 1	1,1	1 549,00	30,98	7	34,65	34,65	1	27,00			1	2,00	2	3,78	36,56
	1,2	1 509,00	30,18	7	34,65										
	1,3	1 538,00	30,76	7	34,65										
	1,4	1 416,00	28,32	6	29,70										
CELLULE 2	2,1	1 018,00	20,36	5	24,75	29,70	1	27,00			1	2,00	1	3,78	32,78
	2,2	1 012,00	20,24	5	24,75										
	2,3	1 300,00	26,00	6	29,70										
CELLULE 3	3,1	1 394,00	27,88	6	29,70	29,70	1	27,00			1	2,00	1	3,78	32,78
	3,2	1 393,00	27,86	6	29,70										
	3,3	1 385,00	27,70	6	29,70										
	3,4	1 309,00	26,18	6	29,70										
CELLULE 5	4,1	1 408,00	28,16	6	29,70	29,70			4	9,00	1	2,00	2	3,78	45,56
	4,2	1 374,00	27,48	6	29,70										
	4,3	1 398,00	27,96	6	29,70										
	4,4	1 290,00	25,80	6	29,70										